



**PREMISES INSPECTION COMMITTEE REPORT**  
**York Endoscopy & Specialist Centre Level 2**  
**Richmond Hill, Ontario**

Following a review of the premises application as a new OHP, their initial site-only Inspection-Assessment Summary and submissions from *York Endoscopy & Specialist Centre*, the Premises Inspection Committee has issued an outcome of Pass with Conditions with the following Condition(s):

**1) As per OHP Standards 4.2 Procedure Room/Operating Room Physical Standards:**

The Committee reviewed your submission that the premises has 15 minutes of back-up power. The Committee has directed that you provide evidence that the premises has enough back-up power to complete procedures as 15 minutes would not be considered enough time.

In order to complete the inspection-assessment process for a new OHP, the inspection-assessment team will return to the premises within 6 months of becoming operational to observe procedures and review record-keeping documentation.